

DECLARATION OF PERFORMANCE

DoP 2 1134-CPR-097

1. **Unique identification code of the product-type:**
MCP
2. **Intended use:**
Fire detection and fire alarm systems for buildings
3. **Manufacturer:**
ARGINA Technics NV, Anthonis De Jonghestraat 50, BE – 9100 Sint-Niklaas,
Tel. +32-(0)3.780.55.20, Fax. +32(0)3.766.37.89, Email: info@argina.com
4. **Authorised representative:**
-
5. **System of AVCP:**
AVCP: 1
6. **Harmonised standard:**
EN 54-11:2001+A1:2005
Notified body:
1134 ANPI, BE
7. **Declared performance:**

Essential characteristics	Performance	Harmonized technical specification
Nominal activation conditions / Sensitivity and Performance under fire conditions	PASS, TYPE A Indoor	EN 54-11:2001+A1:2005 Art: 4.3.2, 4.4, 4.7.1, 5.2, 5.3
Operational reliability	PASS	EN 54-11:2001+A1:2005 Art: 4.2, 4.3.1, 4.5, 4.6, 4.7.2, 4.7.3, 4.7.5, 4.8, 5.4, 5.5
Durability of operational reliability, temperature resistance	PASS	EN 54-11:2001+A1:2005 Art: 5.7, 5.9
Durability of operational reliability, vibration resistance	PASS	EN 54-11:2001+A1:2005 Art: 5.14 to 5.17
Durability of operational reliability, humidity resistance	PASS	EN 54-11:2001+A1:2005 Art: 5.10, 5.12
Durability of operational reliability, corrosion resistance	PASS	EN 54-11:2001+A1:2005 Art: 5.13
Durability of operational reliability, electrical stability	PASS	EN 54-11:2001+A1:2005 Art: 5.6, 5.18

The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

**Signed for and on behalf of the manufacturer by Koen De Maeght, Managing Director
at Sint-Niklaas on 27/03/2018**

